

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 5150 North Street  
**Lab Code:** R2406010-001

**Service Request:** R2406010  
**Date Collected:** 07/02/24 08:53  
**Date Received:** 07/02/24 15:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 5602 County Road 41  
**Lab Code:** R2406010-002

**Service Request:** R2406010  
**Date Collected:** 07/02/24 08:29  
**Date Received:** 07/02/24 15:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 4846 State Route 96  
**Lab Code:** R2406010-003

**Service Request:** R2406010  
**Date Collected:** 07/02/24 09:09  
**Date Received:** 07/02/24 15:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 4500 Fox Road  
**Lab Code:** R2406010-004

**Service Request:** R2406010  
**Date Collected:** 07/02/24 08:05  
**Date Received:** 07/02/24 15:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 6026 State Route 96  
**Lab Code:** R2406010-005

**Service Request:** R2406010  
**Date Collected:** 07/02/24 07:44  
**Date Received:** 07/02/24 15:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/02/24 17:19	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 1299 State Route 332  
**Lab Code:** R2406340-001

**Service Request:** R2406340  
**Date Collected:** 07/11/24 08:04  
**Date Received:** 07/11/24 16:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 5290 North Street  
**Lab Code:** R2406340-002

**Service Request:** R2406340  
**Date Collected:** 07/11/24 08:55  
**Date Received:** 07/11/24 16:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 130 Hook Road  
**Lab Code:** R2406340-003

**Service Request:** R2406340  
**Date Collected:** 07/11/24 07:44  
**Date Received:** 07/11/24 16:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 1000 County Road 8  
**Lab Code:** R2406340-004

**Service Request:** R2406340  
**Date Collected:** 07/11/24 08:22  
**Date Received:** 07/11/24 16:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 1802 State Route 332  
**Lab Code:** R2406340-005

**Service Request:** R2406340  
**Date Collected:** 07/11/24 08:38  
**Date Received:** 07/11/24 16:00

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/11/24 19:01	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** Andrews Road  
**Lab Code:** R2406585-001

**Service Request:** R2406585  
**Date Collected:** 07/18/24 08:46  
**Date Received:** 07/18/24 14:15

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Present	CFU/100mL	-	1	07/18/24 15:26	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	

Report Serial #: 24July Farm. Pos  
 Date prepared: 7/22/2024  
 Prepared by: Eric Feistel  
 Date issued to client: 7/22/2024  
 Sent Via: email  
 Office: 924-3156

City of Canandaigua  
 Water Treatment Facility  
 3772 West Lake Road  
 Canandaigua, NY 14424  
 (585) 396-5064 phone  
 (585) 396-5003 fax

**Laboratory Results**  
 (ELAP certified lab # 109110)

If you have questions about the information in this report, contact Technical Director Peter Vitorio or Quality Assurance Officer Eric Feistel 585-396-5064

Client  
 Town of Farmington

Method: Coliform\* Metric: Coliforms\* Analyzer: Coliform Tester Sample Type: Grab  
 SM 18-20 9223 EPA 1016

Project Name  
 Bact. Testing

Did all samples meet acceptance requirements?  
 Yes  
 (If no, explanation will follow below.)

Sample date	Bottle code	Submitted by	Sample location	Time sampled	Sample size (ml)	Sample received	% Chlorine residual (mash)	Date tested	Time tested	Total coliform	F. colif	Analysis
7/19/2024	1	Chris Van orden	Andrews rd vault	3:30 PM	100	7/19, 4:20 PM	0.51	7/19/2024	4:50 PM	N	N	ESF
7/19/2024	2	Chris Van orden	2478 Andrews rd	3:45 PM	100	7/19, 4:20 PM	0.41	7/19/2024	4:50 PM	N	N	ESF
7/19/2024	3	Chris Van orden	2440 Andrews rd	4:00 PM	100	7/19, 4:20 PM	0.34	7/19/2024	4:50 PM	N	N	ESF

↑  
 Repeat  
 Negative result

*Eric Feistel*

Recorded by: \_\_\_\_\_  
 Quality Assurance Officer  
\*This is a presence/absence test. N indicates negative (no growth) and P indicates positive (excess growth).  
 \*\*Percent of Chlorine residual analysis provided by the client.

The information in this report is accurate to the best of our knowledge and ability. In no event should our liability exceed the cost of these services. These results relate ONLY to the items listed or to the sample AS RECEIVED by this laboratory. This report may not reproduced except in full, without the written approval of this laboratory.

The City of Canandaigua Water Supply Facility Laboratory retains all paper and electronic records of analytical results for a minimum of ten years. By submitting samples to the City of Canandaigua Water Supply Facility Laboratory for analysis, the client agrees that records generated by their submission of samples will be returned to the client in the event that the City of Canandaigua Water Supply Facility Laboratory transfers ownership or goes out of business. It shall be the client's responsibility to transfer their records to another laboratory, or to maintain them themselves.

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** County Rd 8 & Townline Rd  
**Lab Code:** R2406585-002

**Service Request:** R2406585  
**Date Collected:** 07/18/24 08:22  
**Date Received:** 07/18/24 14:15

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 135 Hook Road  
**Lab Code:** R2406585-003

**Service Request:** R2406585  
**Date Collected:** 07/18/24 07:41  
**Date Received:** 07/18/24 14:15

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 6180 Collett Road W  
**Lab Code:** R2406585-004

**Service Request:** R2406585  
**Date Collected:** 07/18/24 08:07  
**Date Received:** 07/18/24 14:15

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 2531 State Route 332  
**Lab Code:** R2406585-005

**Service Request:** R2406585  
**Date Collected:** 07/18/24 08:34  
**Date Received:** 07/18/24 14:15

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/18/24 15:26	



ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 2420 Brickyard Road  
**Lab Code:** R2406831-001

**Service Request:** R2406831  
**Date Collected:** 07/25/24 09:05  
**Date Received:** 07/25/24 14:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 6215 State Route 96  
**Lab Code:** R2406831-002

**Service Request:** R2406831  
**Date Collected:** 07/25/24 10:11  
**Date Received:** 07/25/24 14:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** County Rd 28 & County Rd 41  
**Lab Code:** R2406831-003

**Service Request:** R2406831  
**Date Collected:** 07/25/24 08:38  
**Date Received:** 07/25/24 14:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 187 County Road 8  
**Lab Code:** R2406831-004

**Service Request:** R2406831  
**Date Collected:** 07/25/24 09:51  
**Date Received:** 07/25/24 14:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	

ALS Group USA, Corp.  
dba ALS Environmental

Analytical Report

**Client:** Town of Farmington Consolidated Water and Sewer District  
**Project:** Drinking Water  
**Sample Matrix:** Drinking Water  
**Sample Name:** 5102 North Road  
**Lab Code:** R2406831-005

**Service Request:** R2406831  
**Date Collected:** 07/25/24 08:18  
**Date Received:** 07/25/24 14:20

**Basis:** NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Coliform, Total	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	
Escherichia coli	SM 9223 B	Absent	CFU/100mL	-	1	07/25/24 16:54	